

3000 AMP / 3 PHASE TERMINATION CABINET

- TERMINATION CABINETS ARE CONSTRUCTED WITH ALL WELDED SEAMS. MATERIAL IS GALVANNEALED SHEET STEEL CONFORMING WITH ASTM A653. FINISH IS POWDER COATED ANSI 61 GRAY.
- HINGED DOOR PROVIDED WITH CONTINUOUS, STAINLESS STEEL PIANO HINGE. 3 POINT LATCHING MECHANISM SUPPLIED WITH PADLOCKABLE HANDLE. BOTTOM IS OPEN WITH A 1.5" INTERNAL FLANGE AND $\frac{5}{6}$ " HOLES FOR MOUNTING.
- BUSBARS ARE FABRICATED FROM ALUMINUM ALLOY BAR STOCK, ¼" THICK, 6101-T61 IN ACCORDANCE WITH ASTM B317. BUSBARS ARE PUNCHED TO ACCOMMODATE STANDARD 2 HOLE HIGH-PRESS LUGS.
- POWER TERMINATION CABINETS ARE CONSTRUCTED IN ACCORDANCE WITH UL BULLETIN #50 AND NEMA 3R SPECIFICATIONS.

DOMINION VIRGINIA POWER APPROVED PART# PPTCDV3

/			
()	DWG. TITLE:	3000 AMP / 3 PHASE	
		TERMINATION CABINET	
	DWG. NO.:	P10124	
	MATERIAL:	ASTM A653 GALVANNEALED	
	FINISH:	ANSI 61 GRAY	
\			_


1	NOTICE:
	THIS INFORMATION IS THE PROPERTY OF N.J.
	SULLIVAN CO., ANY REPRODUCTION, PUBLICATION
	OR DISTRIBUTION TO A THIRD PARTY IS STRICKLY
	FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE
	GIVEN BY AN AUTHORIZED AGENT OF:
	N.J. SULLIVAN CO., INC.
	N.S. SOLLIVAN CO., INC.
	DETG.: CD DATE: 4/1/15

N.J. SULLIVAN CO., INC.				
DFTG.:	CD	DATE:	4/1/15	
CHKR.:		DATE:		
REV.:		DATE:		
REV.:		DATE:		
REV.:		DATE:		



Technical Specification

BOTTOM VIEW FOR FOR PART PPTCDV3



DWG. TITLE:	Mounting Flange for	
	PARTS PPTCDV3	
DWG. NO.:	P10126	
MATERIAL:	ASTM A653 GALVANNEALED	
FINISH:	ANSI 61 GRAY	

	_
,	
N.J. SULLIVAN CO., INC.	
GIVEN BY AN AUTHORIZED AGENT OF:	
FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE	
OR DISTRIBUTION TO A THIRD PARTY IS STRICKLY	•
SULLIVAN CO., ANY REPRODUCTION, PUBLICATION	
THIS INFORMATION IS THE PROPERTY OF N.J.	
NOTICE.	

DFTG.:	CD	DATE:	4/1/15
CHKR.:		DATE:	
REV.:		DATE:	
REV.:		DATE:	
REV.:		DATE:	

